

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400

Group Number Assessment

(In accordance with AS 5637.1-2015)

This is to confirm that the product as described below has been tested by AWTA Product Testing.

Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

As per AS 5637.1 Clause 9(n) it was valid to test this particular material / system in the cone calorimeter for the assignment of a NCC Group Number.

Test Sponsor :	SAS Supplier Group Pty Ltd	Test Number :	21-002065
	39-41 Oversea Drive	Issue Date :	11/05/2021
	Noble Park VIC 3174	Print Date :	18/10/2022

Sponsor Product :	Clients Ref :	"Colour Coated Solid Aluminium Sheet (Ai Panel)"
	Rigid panel	
	Colour :	Charcoal
	End Use :	External building cladding
	Nominal Composition :	Marine grade (5052) aluminium alloy with PVDF matte cobur coating
	Nominal Mass per Unit Area/Density :	2680kg/m3
	Nominal Thickness :	2mm

Product Group Number Classification : 1

Average Specific Extinction Area : 28.6 m²/kg



Fiona McDonald
Testing Technologist

51284

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. Its transmission is not intended to place the contents into the public domain.

If you have received this transmission in error, its disclosure or copying is prohibited. Please contact us by collect call so that arrangements can be made at our expense to rectify the error.